



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Greater Brunswick Charter School (9282), 429 Joyce Kilmer Ave., New Brunswick, NJ

PAS Project ID : P25-06109

Matrix : Drinking Water

Report Date : 7/10/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-06109-01	GBCS-1-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:52	7/3/25 09:56
P25-06109-02	GBCS-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:52	7/3/25 10:01
P25-06109-03	GBCS-1-WC02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:52	7/3/25 10:05
P25-06109-04	GBCS-1-BF02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:52	7/3/25 10:10
P25-06109-05	GBCS-1-DS01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:54	7/3/25 10:23
P25-06109-06	GBCS-1-WC03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:56	7/3/25 10:28
P25-06109-07	GBCS-1-BF03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:06	7/3/25 10:32
P25-06109-08	GBCS-1-WC04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:58	7/3/25 10:37
P25-06109-09	GBCS-1-BF04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:58	7/3/25 10:42
P25-06109-10	GBCS-1-S01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:59	7/3/25 10:46
P25-06109-11	GBCS-1-S02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 08:59	7/3/25 10:51
P25-06109-12	GBCS-1-WC05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 09:01	7/3/25 10:55
P25-06109-13	GBCS-1-BF05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 09:01	7/3/25 11:00
P25-06109-14	GBCS-1-WC06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 09:02	7/3/25 11:13
P25-06109-15	GBCS-1-BF06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 09:02	7/3/25 11:31
P25-06109-16	GBCS-6-20-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/25 09:03	7/3/25 11:35

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer