

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at [http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>LONG VALLEY CHARTER SCHOOL</b>
Water System Number:	<b>CA1800576</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/10/2026 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Jerad Morgan	
	Signature:	<i>Jerad Morgan</i>	
	Title:	Assistant Director	
	Phone Number:	( 530 ) 832-5507	Date: 6/10/2026

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
 CCR was distributed through Parent Square app directly to all families and staff

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at [http:// longvalleycs.org](http://longvalleycs.org)
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places: Long Valley School, USPS Doyle, & USPS Herlong
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://>\_\_\_\_\_

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2025 Consumer Confidence Report

Water System Name: LONG VALLEY CHARTER SCHOOL

Report Date: February 2026

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well 01

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held at 436965 Susan Drive, Doyle CA 96109 Bi-Annually on the 2nd Wednesday of the month @5:30pm.

For more information about this report, or any questions relating to your drinking water, please call and ask for Sherri Morgan or email [smorgan@longvalleycs.org](mailto:smorgan@longvalleycs.org).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Table(s) 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	(2024)	5	0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	(2024)	5	0.07	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2024)	31	26 - 35	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2024)	97.8	84.6 - 111	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2024 - 2025)	8	5 - 15	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Chromium (ug/L)	(2024)	ND	ND - 10	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	(2024)	0.3	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2024 - 2025)	2.6	2.1 - 3.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2024)	3	2.4 - 3.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2024)	14.2	10.1 - 18.3	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2024)	12.7	12.0 - 13.4	20	0.43	Erosion of natural deposits

<b>Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Chloride (mg/L)	(2024)	8	7 - 8	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2024)	333	318 - 348	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2024)	28.8	28.4 - 29.2	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2024)	190	160 - 220	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2024)	0.1	n/a	5	n/a	Soil runoff
Zinc (mg/L)	(2024)	0.02	0.01 - 0.02	5	n/a	Runoff/leaching from natural deposits

<b>Table 5 - DETECTION OF UNREGULATED CONTAMINANTS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Health Effects</b>
Vanadium (ug/L)	(2024)	31	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

<b>Table 6 - ADDITIONAL DETECTIONS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>
Calcium (mg/L)	(2024)	26	24 - 28	n/a	n/a
Magnesium (mg/L)	(2024)	8	6 - 10	n/a	n/a
pH (units)	(2024)	7.95	7.73 - 8.16	n/a	n/a
Alkalinity (mg/L)	(2024)	125	120 - 130	n/a	n/a
Aggressiveness Index	(2024)	11.9	11.7 - 12.0	n/a	n/a
Langelier Index	(2024)	0.1	-0.1 - 0.2	n/a	n/a

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ

transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Long Valley Charter School* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Gross Alpha				Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

**About your Arsenic:** For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## 2025 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

A source water assessment was conducted for the WELL 01 of the LONG VALLEY CHARTER SCHOOL water system in November, 2001.

Well 01 - is considered most vulnerable to the following activities associated with contaminants detected in the water supply:

- Sewer collection systems
- Pesticide/fertilizer/petroleum storage & transfer areas
- Agricultural Drainage
- Fertilizer/Pesticide/Herbicide Application
- Sewage sludge/biosolids application
- Septic systems - low density [ $<1$ /acre]
- Crops, nonirrigated [e.g., Christmas trees, grains, grass seeds, hay]

is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Gas stations
- Chemical/petroleum processing/storage

### **Discussion of Vulnerability**

Due to the detection of Nitrate (as N03) detected in the month of July 2000, and Nitrate + Nitrite (as N) detected in the month of September 1997, Well 01 is considered most vulnerable to activities that may have contributed to or caused the release of Nitrates. Nitrate is associated with runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits. Both of these chemicals have been nondetected since. During September 2000 Well 01 tested positive for Fluoride. This chemical is associated with the erosion of natural deposits; discharge from fertilizer and aluminum factories and is a water additive that promotes strong teeth. This particular chemical has been nondetected since. Well 01 is also considered to be vulnerable to Arsenic. Arsenic is associated with runoff from orchards, glass and electronics production wastes, and erosion of natural deposits. This chemical has been nondetected since.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:

Long Valley Charter School  
P.O. Box 7  
Doyle, Ca 96109

You may request a summary of the assessment be sent to you by contacting:

Michael McNamara  
Assoc. Sanitary Engineer  
(530) 224-4800



<b>Lead</b>		ug/L	0	15	0.2			0	5
Apao Class Room Sink	CH 2476556-5	ug/L				2024-07-24	ND		
Kitchen Sink	CH 2476556-1	ug/L				2024-07-24	ND		
Multipurpose Drinking	CH 2476556-2	ug/L				2024-07-24	ND		
Outside Drinking Fountain	CH 2476556-3	ug/L				2024-07-24	ND		
Tinker Lab Sink	CH 2476556-4	ug/L				2024-07-24	ND		
<b>Copper</b>		mg/L		1.3	.3			0.065	5
Apao Class Room Sink	CH 2476556-5	mg/L				2024-07-24	0.06		
Kitchen Sink	CH 2476556-1	mg/L				2024-07-24	ND		
Multipurpose Drinking	CH 2476556-2	mg/L				2024-07-24	ND		
Outside Drinking Fountain	CH 2476556-3	mg/L				2024-07-24	ND		
Tinker Lab Sink	CH 2476556-4	mg/L				2024-07-24	0.07		

**SAMPLING RESULTS FOR SODIUM AND HARDNESS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			31	26 - 35
WELL 01	CH 2475357-1	mg/L				2024-06-27	26		
Well 01	CH 2471397-1	mg/L				2024-03-06	35		
<b>Hardness</b>		mg/L		none	none			97.8	84.6 - 111
WELL 01	CH 2475357-1	mg/L				2024-06-27	111		
Well 01	CH 2471397-1	mg/L				2024-03-06	84.6		

**PRIMARY DRINKING WATER STANDARDS (PDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			8	5 - 15
WELL 01	CH 2579798-1	ug/L				2025-10-01	5		
WELL 01	CH 2576539-1	ug/L				2025-07-09	6		
WELL 01	CH 2574080-1	ug/L				2025-05-14	6		
Well 01	CH 2471397-1	ug/L				2024-03-06	15		
<b>Chromium</b>		ug/L	100	50.0	n/a			ND	ND - 10
WELL 01	CH 2475357-1	ug/L				2024-06-27	10		
Well 01	CH 2471397-1	ug/L				2024-03-06	ND		
<b>Fluoride</b>		mg/L		2	1			0.3	0.3 - 0.3
WELL 01	CH 2475357-1	mg/L				2024-06-27	0.3		
Well 01	CH 2471397-1	mg/L				2024-03-06	0.3		
<b>Nitrate as N</b>		mg/L		10	10			2.6	2.1 - 3.5
Well 01	CH 2572435-1	mg/L				2025-03-26	2.3		
Well 01	CH 2571762-1	mg/L				2025-03-12	2.1		
WELL 01	CH 2475357-1	mg/L				2024-06-27	3.5		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			3.0	2.4 - 3.5
WELL 01	CH 2475357-1	mg/L				2024-06-27	3.5		
Well 01	CH 2471397-1	mg/L				2024-03-06	2.4		
<b>Gross Alpha</b>		pCi/L		15	(0)			14.2	10.1 - 18.3
WELL 01	CH 2475357-1	pCi/L				2024-06-27	10.1		
Well 01	CH 2471397-1	pCi/L				2024-03-06	18.3		
<b>Uranium</b>		pCi/L		20	0.43			12.7	12.0 - 13.4
WELL 01	CH 2475357-1	pCi/L				2024-06-27	12.0		
Well 01	CH 2471397-1	pCi/L				2024-03-06	13.4		

**SECONDARY DRINKING WATER STANDARDS (SDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			8	7 - 8
WELL 01	CH 2475357-1	mg/L				2024-06-27	8		
Well 01	CH 2471397-1	mg/L				2024-03-06	7		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			333	318 - 348
WELL 01	CH 2475357-1	umhos/cm				2024-06-27	348		
Well 01	CH 2471397-1	umhos/cm				2024-03-06	318		

<b>Sulfate</b>		mg/L		500	n/a			28.8	28.4 - 29.2
WELL 01	CH 2475357-1	mg/L				2024-06-27	29.2		
Well 01	CH 2471397-1	mg/L				2024-03-06	28.4		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			190	160 - 220
WELL 01	CH 2475357-1	mg/L				2024-06-27	220		
Well 01	CH 2471397-1	mg/L				2024-03-06	160		
<b>Turbidity</b>		NTU		5	n/a			0.10	0.10 - 0.10
Well 01	CH 2471397-1	NTU				2024-03-06	0.10		
<b>Zinc</b>		mg/L		5	n/a			0.02	0.01 - 0.02
WELL 01	CH 2475357-1	mg/L				2024-06-27	0.02		
Well 01	CH 2471397-1	mg/L				2024-03-06	0.01		

**UNREGULATED CONTAMINANTS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Vanadium</b>		ug/L		NS	n/a			31	31 - 31
Well 01	CH 2471397-1	ug/L				2024-03-06	31		

**ADDITIONAL DETECTIONS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			26	24 - 28
WELL 01	CH 2475357-1	mg/L				2024-06-27	28		
Well 01	CH 2471397-1	mg/L				2024-03-06	24		
<b>Magnesium</b>		mg/L			n/a			8	6 - 10
WELL 01	CH 2475357-1	mg/L				2024-06-27	10		
Well 01	CH 2471397-1	mg/L				2024-03-06	6		
<b>pH</b>		units			n/a			7.95	7.73 - 8.16
WELL 01	CH 2475357-1	units				2024-06-27	7.73		
Well 01	CH 2471397-1	units				2024-03-06	8.16		
<b>Alkalinity</b>		mg/L			n/a			125	120 - 130
WELL 01	CH 2475357-1	mg/L				2024-06-27	130		
Well 01	CH 2471397-1	mg/L				2024-03-06	120		
<b>Aggressiveness Index</b>					n/a			11.9	11.7 - 12.0
WELL 01	CH 2475357-1					2024-06-27	11.7		
Well 01	CH 2471397-1					2024-03-06	12.0		
<b>Langelier Index</b>					n/a			0.1	-0.1 - 0.2
WELL 01	CH 2475357-1					2024-06-27	-0.1		
Well 01	CH 2471397-1					2024-03-06	0.2		

# Long Valley Charter School

## CCR Login Linkage - 2025

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CA1800576_LCR	CH 2476556-5	2024-07-24	Metals, Total	Apao Class Room Sink	LONG VALLEY CHARTER SCHOOL
CR WF	CH 2570730-4	2025-01-29	Coliform	Class Room Water Fountain Miss	Bacteriological Monitoring
	CH 2571225-4	2025-02-19	Coliform	Class Room Water Fountain Miss	Bacteriological Monitoring
	CH 2571763-4	2025-03-12	Coliform	Class Room Water Fountain Miss	Bacteriological Monitoring
	CH 2572895-4	2025-04-09	Coliform	Class Room Water Fountain Miss	Bacteriological Monitoring
	CH 2574079-4	2025-05-14	Coliform	Class Room Water Fountain Miss	Bacteriological Monitoring
ENTRNC HW WF	CH 2570730-2	2025-01-29	Coliform	Entrance Hallway Water Fountai	Bacteriological Monitoring
	CH 2571225-2	2025-02-19	Coliform	Entrance Hallway Water Fountai	Bacteriological Monitoring
	CH 2571763-2	2025-03-12	Coliform	Entrance Hallway Water Fountai	Bacteriological Monitoring
	CH 2572895-2	2025-04-09	Coliform	Entrance Hallway Water Fountai	Bacteriological Monitoring
	CH 2574079-2	2025-05-14	Coliform	Entrance Hallway Water Fountai	Bacteriological Monitoring
CA1800576_LCR	CH 2476556-1	2024-07-24	Metals, Total	Kitchen Sink	LONG VALLEY CHARTER SCHOOL
	CH 2476556-2	2024-07-24	Metals, Total	Multipurpose Drinking	LONG VALLEY CHARTER SCHOOL
OffsSnk	CH 2570730-1	2025-01-29	Coliform	Office Sink	Bacteriological Monitoring
	CH 2571225-1	2025-02-19	Coliform	Office Sink	Bacteriological Monitoring
	CH 2571763-1	2025-03-12	Coliform	Office Sink	Bacteriological Monitoring
	CH 2572895-1	2025-04-09	Coliform	Office Sink	Bacteriological Monitoring
	CH 2574079-1	2025-05-14	Coliform	Office Sink	Bacteriological Monitoring
	CH 2575293-1	2025-06-11	Coliform	Office Sink	Bacteriological Monitoring
	CH 2576538-1	2025-07-09	Coliform	Office Sink	Bacteriological Monitoring
	CH 2578112-1	2025-08-13	Coliform	Office Sink	Bacteriological Monitoring
	CH 2579341-1	2025-09-17	Coliform	Office Sink	Bacteriological Monitoring
	CH 2579799-1	2025-10-01	Coliform	Office Sink	Bacteriological Monitoring
	CH 2591268-1	2025-11-19	Coliform	Office Sink	Bacteriological Monitoring
	CH 2591695-1	2025-12-03	Coliform	Office Sink	Bacteriological Monitoring
CA1800576_LCR	CH 2476556-3	2024-07-24	Metals, Total	Outside Drinking Fountain	LONG VALLEY CHARTER SCHOOL
	CH 2476556-4	2024-07-24	Metals, Total	Tinker Lab Sink	LONG VALLEY CHARTER SCHOOL
WF BK MB	CH 2572895-3	2025-04-09	Coliform	Water Fountain on Back of Main	Bacteriological Monitoring
	CH 2574079-3	2025-05-14	Coliform	Water Fountain on Back of Main	Bacteriological Monitoring
WELL 01	CH 2471397-1	2024-03-06	General Mineral	Well 01	Water Quality Monitoring
	CH 2471397-1	2024-03-06	Metals, Total	Well 01	Water Quality Monitoring
	CH 2471397-1	2024-03-06	Radio Chemistry	Well 01	Water Quality Monitoring
	CH 2471397-1	2024-03-06	Wet Chemistry	Well 01	Water Quality Monitoring
	CH 2475357-1	2024-06-27	General Mineral	WELL 01	Water Quality Monitoring - 2
	CH 2475357-1	2024-06-27	Metals, Total	WELL 01	Water Quality Monitoring - 2
	CH 2475357-1	2024-06-27	Radio Chemistry	WELL 01	Water Quality Monitoring - 2
	CH 2571762-1	2025-03-12	Wet Chemistry	Well 01	Water Quality Monitoring
	CH 2572435-1	2025-03-26	Wet Chemistry	Well 01	Water Quality Monitoring
	CH 2574080-1	2025-05-14	Metals, Total	WELL 01	Arsenic Monitoring
	CH 2576539-1	2025-07-09	Metals, Total	WELL 01	Arsenic Monitoring
	CH 2579798-1	2025-10-01	Metals, Total	WELL 01	Arsenic Monitoring