



Corning Union Elementary School District  
1005 Hoag Street  
Corning, CA 96021

---

**BID DOCUMENTS**  
**Hard Bid RFP for Maywood Fire Alarm Replacement**

---

**ADDENDA**

The changes, modifications, corrections or clarifications herein set forth shall be incorporated as part of the above-referenced documents issued under due date as of no later than 2:00PM on Thursday, May 7, 2026; and shall supersede said documents only as stated. All other conditions remain unchanged. The proposer must acknowledge receipt of the Addendum; failure to do so may subject the proposer to disqualification.

---

**ADDENDUM No. 2 – April 29, 2026:**

Please see below and attached.

**IMPORTANT DATES TO REMEMBER:**

Proposals Due: ~~no later than 2:00PM on May 6, 2026~~  
**no later than 2:00PM on May 7, 2026**

**CLARIFICATIONS:**

1. Please see the “Important Dates to Remember” section above for a change to the due date.

**BID OPENING**

The bid opening will take place virtually on Wednesday, May 7, 2026 at 2:00pm. Please join the virtual bid opening using the following link:

Maywood Fire Alarm Bid Opening

Thursday, May 7 · 2:00 – 3:00pm

Time zone: America/Los\_Angeles

Google Meet joining info

Video call link: <https://meet.google.com/pkx-kiqz-udq>

Or dial: (US) +1 269-820-1090 PIN: 278 762 781#

More phone numbers: <https://tel.meet/pkx-kiqz-udq?pin=9108064980521>

**QUESTIONS**

1. Sheet FA2.1, General Note 1 states “Demolish campus wide fire alarm system in its entirety. This includes all fire alarm equipment, initiating devices, notification appliances, cabling, conduit, and any other related materials.”

Most of the devices on the walls are being replaced with speaker/strobes and have existing boxes and conduit stubs. Can we reuse the existing boxes and raceways and modify the boxes to house speaker/strobes.

- a. We take no exceptions to the reuse of boxes and raceways if they are found to be in good condition.

***\*Additional questions received will be addressed in a future addendum.\****