

ADDENDUM NO. 1

**BONITA UNIFIED SCHOOL DISTRICT
BID NO. 2025-26-07
ASPHALT AT VARIOUS SITES**

The following clarifications, responses, changes, additions, deletions, or corrections shall become part of this solicitation and the contract documents for the bid named above.

1. Is the District willing to accept an A license?

The contractor's license at the time that the contract is awarded should be a Class C12-Earthwork and Paving License.

2. For bidding purposes are we to bid with all three sites to have petromat or without petromat?

Yes, if no petromat is found your invoices should reflect the lower price.

3. Will there be any seal coat on new asphalt areas?

Yes.

4. Shull Elementary. We are to set header along grass area Planter area, and along the Enite south wall area as well?

Walls and buildings shouldn't have a redwood header it should have a small gap with a sealant.

5. San Dimas High School. Per my discussion with Dane. Would you like to change the scope of work to remove only the upper portion and seal coat the lower area. Due to the lower area looked like it was still in really good condition. See attached illustration.

This will work; please see the picture below. I have added additional seal and stripe to the south end of the drop-off area. This adjustment aligns with the removal of the north asphalt.



END OF ADDENDUM NO. 1

BELOW, PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND SUBMIT IT WITH YOUR BID.

Company Name: _____

Signature: _____

Print Name: _____

Title: _____

Date: _____