



Corning Union Elementary School District
1005 Hoag Street
Corning, CA 96021

BID DOCUMENTS

Informal CUPCCAA RFP for Maywood Middle School Fencing
Project

ADDENDA

The changes, modifications, corrections or clarifications herein set forth shall be incorporated as part of the above-referenced documents issued under due date as of no later than 2:00PM on **Friday, October 24, 2025**; and shall supersede said documents only as stated. All other conditions remain unchanged. The proposer must acknowledge receipt of the Addendum; failure to do so may subject the proposer to disqualification.

ADDENDUM No. 3 – October 20, 2025:

Please see below.

IMPORTANT DATES TO REMEMBER:

Proposals Due: ~~no later than 2:00PM on October 23, 2025~~
no later than 2:00PM on October 24, 2025

CLARIFICATIONS

1. The existing fencing to be matched is 7 feet tall.

QUESTIONS

1. Please confirm that there are to pedestrian panic access gates and fence is 6' tall also confirm panic hardware specification.
 - a. Yes. The two man gates are pedestrian gates equipped with panic hardware. The fence will be **7 feet tall**. The panic hardware is Von Duprin 99 Series, paired with Lockinox Mammoth hinges