



**Corning Union Elementary School District
1005 Hoag Street
Corning, CA 96021**

**BID DOCUMENTS
Hard Bid RFP for Maywood Fire Alarm Replacement**

ADDENDA

The changes, modifications, corrections or clarifications herein set forth shall be incorporated as part of the above-referenced documents issued under due date as of no later than 2:00PM on Thursday, May 7, 2026; and shall supersede said documents only as stated. All other conditions remain unchanged. The proposer must acknowledge receipt of the Addendum; failure to do so may subject the proposer to disqualification.

ADDENDUM No. 3 – May, 4, 2026:

Please see below.

IMPORTANT DATES TO REMEMBER:

Proposals Due: **no later than 2:00PM on May 7, 2026**

BID OPENING

The bid opening will take place virtually on Thursday, May 7 , 2026 at 2:00pm. Please join the virtual bid opening using the following link:

Maywood Fire Alarm Bid Opening

Thursday, May 7 · 2:00 – 3:00pm

Time zone: America/Los_Angeles

Google Meet joining info

Video call link: <https://meet.google.com/pkx-kiqz-udq>

Or dial: (US) +1 269-820-1090 PIN: 278 762 781#

More phone numbers: <https://tel.meet/pkx-kiqz-udq?pin=9108064980521>

QUESTIONS

1. Is free air fire alarm cabling acceptable above t-bar and attic spaces?
 - a. Fire alarm wiring above t-bar ceiling and in attic spaces is to be free air. Wiring is to comply with Table 760.176 of the 2025 CFC.